

**TIERED PRESCRIPTIVE COMPLIANCE
SECTION 9.36. OF THE NATIONAL BUILDING CODE OF CANADA**

This form is intended to clarify the compliance with Section 9.36. prescriptive path.

Must be completed by a competent person who is knowledgeable, experienced, and trained in building design under Section 9.36 of the NBC and acceptable to the Authority Having Jurisdiction.

Project Information			
Address:			Climate Zone: 7A
Occupancy Class:		Conditioned Space Volume (m ³):	
Select Performance Tier	<input type="checkbox"/> Tier 1	<input type="checkbox"/> Tier 2	<input type="checkbox"/> Tier 3 <input type="checkbox"/> Tier 4 <input type="checkbox"/> Tier 5
Energy prescriptive compliance paths apply to: <ul style="list-style-type: none"> Buildings of residential occupancy to which Part 9 applies. Buildings containing business and personal services, mercantile or low hazard industrial occupancies to which Part 9 applies to whose combined floor area does not exceed 300 m², excluding parking garages serving residential occupancies, and Buildings containing any mixture of the above two. 			

Prescriptive Compliance Path (Subsection 9.36.2. – 9.36.4.)

All calculations and specifications must be attached to this form to be considered complete and be accepted for review.

Conversions:	
$R = 5.678 \times \text{RSI}$	$U = 1 / \text{RSI}$

HRV / ERV: ☐ Yes ☐ No

Effective Thermal Resistance of Above Ground Opaque Building Assemblies (RSI)			
Assembly	w/ HRV	w/o HRV	Proposed
Ceilings below attics	8.67	10.43	
Cathedral / Flat roofs	5.02	5.02	
Walls & Rim joists	2.97	3.08	
Floors over unheated spaces	5.02		
Floors within garage	4.86		
Thermal Characteristics of Fenestration, Doors and Skylights (U)			
Assembly	Efficiency		Proposed
Windows & Doors	Maximum U-Value 1.61 or Minimum Energy Rating > 25 Maximum U-Value 2.60		
One door exception			
Attic hatch	Minimum RSI _{nom} 2.60		
Skylights	Maximum U-Value 2.75		
Effective Thermal Resistance of Below-Grade or In-Contact-With-Ground Opaque Buildings Assemblies (RSI)			
Assembly	w/ HRV	w/o HRV	Proposed
Foundation Walls	2.98	3.46	
Slab On Grade With Integral Footing	2.84	3.72	
Unheated Floor Below Frost Line	uninsulated	uninsulated	
Unheated Floor Above Frost Line	1.96	1.96	
Heated Floors	2.84	2.84	

Trade Off Compliance Path (9.36.2.11.): ☐ Yes ☐ No

Should trade off be proposed, all calculations must be attached to this form to be considered complete and be accepted for review. The location and extent of assemblies used in the calculations shall be clearly identified on the drawings by hatch or note.

TIERED PRESCRIPTIVE COMPLIANCE
SECTION 9.36. OF THE NATIONAL BUILDING CODE OF CANADA

HVAC Equipment Performance Requirements				
Equipment	Capacity KW	Standard	Min. Efficiency	Proposed
Electric Heat Pump (split & single package)	≥ 19	See Tables 5.2.12.1.-A to -P of Division B of the NECB		
Gas Fired Furnace w or w/o A/C	≤ 66 using single-phase electric current	CAN/CSA-P.2	AFUE ≥ 95% and must be equipped with a high-efficiency constant torque or constant airflow fan motor	
	≤ 66, through the wall furnace		E _t ≥ 78.5% AFUE > 90%	
	≤ 66 using three-phase electric current	ANSI Z21.47/CSA 2.3	AFUE ≥ 78% or E _t ≥ 80%	
	> 66 and ≤ 117.23		E _t ≥ 80%	
Electric Boiler	< 88	(1)		
Gas Fired Boiler	< 88	CAN/SCA-P.2	AFUE ≥ 90%	
	≥ 88 & < 733	ANSI/AHRI 1500 or DOE 10 CFR, Part 431, Subpart E, Appendix A	E _t ≥ 83%	
Other				
Heat Loss/Heat Gain Calculation	<input type="checkbox"/> Calculations were prepared in conformance with CSA F280-12			BTU
Nomenclature	AFUE= annual fuel utilization efficiency, E _t = thermal efficiency			
(1) Must be equipped with automatic water temperature control. No standard addresses the performance efficiency; however their efficiency typically approaches 100%				
Water Heaters Performance Requirements				
Equipment	Capacity KW	Standard	Min. Efficiency	Proposed
Tank Storage Electric	≤ 12 kW (>50 L to ≤ 270 L capacity)	CAN/CSA-C191	SL ≤ 35 + 0.20V (top inlet)	
			SL ≤ 40 + 0.20V (bottom inlet)	
	≤ 12 kW (>270 L to ≤ 454 L capacity)		SL ≤ (0.472V) - 38.5 (top inlet)	
			SL ≤ (0.472V) - 33.5 (bottom inlet)	
	>12 kW	ANSI Z21.10.3/CSA 4.3 or DOE 10 CFR, Part 431, Subpart G App B	SL≤ 0.30 + (102.2 V _s)	
Tank Storage Gas Fired	≤ 22 kW and first-hour rating < 68 L	CAN/CSA-P.3	UEF ≥ 0.3456 – (0.00053 V _s)	
	≤ 22 kW and first-hour rating > 68 L but < 193 L		UEF ≥ 0.5982 – (0.00050 V _s)	
	≤ 22 kW and first-hour rating ≥ 193 L but < 284 L		UEF ≥ 0.6483 – (0.00045 V _s)	
	≤ 22 kW and first-hour rating > 284 L		UEF ≥ 0.6920 – (0.00034 V _s)	
	> 22 kW but ≤ 30.5kW and V _r < 454 L		UEF ≥ 0.8107 – (0.00021 V _s)	
	> 22 kW	DOE 10 CFR, Part 431, Subpart G, Appendix A	E _t ≥ 90% and SL ≤ 0.84 [(1.25 Q) + (16.57 √V _r)]	
Tankless Gas Fired	< 58.56 kW, V _r ≤ 7.6 L and max. flow rate < 6.4 L/min	CAN/CSA-P.3	UEF ≥ 0.86	
	< 58.56 kW, V _r ≤ 7.6 L and max. flow rate ≥ 6.4 L/min		UEF ≥ 0.87	
	≥ 58.56 kW, V _r ≤ 37.85 L and input rate to V _r ratio > 309 W/L	DOE 10 CFR, Part 431, Subpart G, Appendix C	E _t ≥ 94%	

TIERED PRESCRIPTIVE COMPLIANCE
SECTION 9.36. OF THE NATIONAL BUILDING CODE OF CANADA

Tankless, Electric	No standard addresses the performance efficiency; however, their efficiency typically approaches 100%		
Other			
Nomenclature	EF = energy factor	E _t = thermal efficiency with a 38.9°C (70°F) water temp difference	
	Q = nameplate input rate, in kW	SL = standby loss, in W	
	V _r = rated nominal storage volume, in L	V _s = measured storage volume, in L	

Compliance via Tiered Prescriptive Results (9.36.8.): ☐ Yes ☐ No

This option applies only to buildings of residential occupancy to which Part 9 applies.

Energy Performance Measures	Minimum Energy Conservation Points (Zone 7A)
Above-Ground Walls	
Fenestration and Doors	
Below-Grade or In Contact with Ground	
Airtightness	
Ventilation Systems	
Service Water Heating Equipment	
Building Volume	
Total Energy Conservation Points Achieved:	

Where points are achieved through Table 9.36.8.8., an airtightness test is required to be conducted. Provide the Airtightness Certificate to engineering@rmestevan.ca once complete and required prior to scheduling a final inspection.

Declaration	
<i>I hereby certify that the calculations submitted were prepared in full accordance with Section 9.36.</i>	
Print Name _____ Signature _____ Date _____	